



Sanitary Sewer Lateral Pilot Project

ADDENDUM NO. 2

DATE: September 29, 2020

BID OPENING: Thursday, October 1, 2020 @ 2:00:00 P.M.

PAGES: Addendum (2 pages)

.....
Acknowledge receipt of this Addendum by inserting its number and date on the Bid Form. Failure to do so may subject bidder to disqualification. This Addendum forms a part of the Contract Documents. It modifies the Contract Documents as follows:
.....

PART 7, SPECIAL PROVISIONS

SECTION-503 CLEAN-OUTS

Delete Paragraph 2.1.A in its entirety and replace with the following:

- A. Clean-out material shall be Type 3034 PVC (SDR 35), or approved equal, and shall be compatible with the material selected for the lateral replacement.

SECTION-504 SEWER SERVICES

Delete Paragraph 2.2.C in its entirety and replace with the following:

- C. High-Density Polyethylene Pipe and Fittings
 - 1. Reference SP-510, Paragraph 2.1.

Delete Paragraph 2.2.D in its entirety and replace with the following:

- D. Cured-in-Place Pipe (CIPP)
 - 1. Reference SP-509, Paragraph 2.1.

Submitted by:

J-U-B ENGINEERS, Inc.



Christopher J. Horgan, P.E.
Design Engineer, Part 7 and Part 8

END OF ADDENDUM NO. 2